

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

was issued to

Vatan Kablo

Ergene / Tekirdağ, Turkey

for the test object:

four-core

power cable

Type: 0,6/1 kV 4x35 mm² Cu/XLPE/PVC/GSWA/PVC Cable (N2XYRY 0,6/1kV)

Rating: 0,6/1 (1,2) kV – 4x35mm² – Cu - XLPE

manufactured by

Vatan Kablo

Ergene / Tekirdağ, Turkey

The test object has successfully passed the required type tests of


IEC 60502-1

The test results are recorded in Certificate No.

1169-19

This Certificate was issued on 11 June 2019.

KEMA B.V.



Bas Verhoeven
Director, High-Voltage Laboratory

KEMA

Laboratories

© KEMA B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that KEMA B.V. has certified or approved any object other than the specimen tested.

