

# CERTIFICATE

Issued to:  
Applicant:  
**Vatan Kablo**  
**Velimese OSB Mahallesi 111. Sokak No.4/1**  
**Ergene**  
**59880 Velimese, Tekirdag, Turkey**

Licensee:  
**Vatan Kablo Metal End ve Tic A.S.**  
**Perpa Ticaret Merkezi**  
**A-Blok Kat:11 No 1385**  
**Okmeydani**  
**Istanbul, Turkey**

Product : XLPE insulated and PVC sheathed cable  
Trade name(s) : VATAN KABLO  
Type(s)/model(s) : XMvK

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard DEKRA K42C-07-1:2004, DEKRA K42C-07-2:2004 and DEKRA K42C-07-3:2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 6058394


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 6 November 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-115715

DEKRA Certification B.V.



**B.T.M. Holtus**  
Managing Director



**H.R.M. Barends**  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: XLPE insulated and PVC sheathed cable
Trade name(s)	: VATAN KABLO
Type(s)/model(s)	: XMvK
Rated voltage	: 450/750 V
Conductor	: Plain copper class 1
Conductor operating temperature	: 90 °C maximum
Insulation	: XLPE compound
Filler	: Extruded non-hygroscopic compound based on unvulcanised rubber or plastic
Sheath	: PVC compound type PVC/ST
Tested cable	: 3x2,5 mm <sup>2</sup> .
Certified cables	: 2x1,5 mm <sup>2</sup> ~ 2x2,5 mm <sup>2</sup> . 3x1,5 mm <sup>2</sup> ~ 3x2,5 mm <sup>2</sup> / 3G1,5 mm <sup>2</sup> ~ 3G2,5 mm <sup>2</sup> . 4x1,5 mm <sup>2</sup> ~ 4x2,5 mm <sup>2</sup> / 4G1,5 mm <sup>2</sup> ~ 4G2,5 mm <sup>2</sup> . 5x1,5 mm <sup>2</sup> ~ 5x2,5 mm <sup>2</sup> / 5G1,5 mm <sup>2</sup> ~ 5G2,5 mm <sup>2</sup> .

**TESTS****Test requirements**

DEKRA K42C-07-1:2004  
DEKRA K42C-07-2:2004  
DEKRA K42C-07-3:2004

**Test result**

The test results are laid down in DEKRA test file 224811300.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

Vatan Kablo  
Velimese OSB Mahallesi 111. Sokak No.4/1 Ergene  
59880 Velimese, Tekirdag, Turkey