

LICENCE

No. 22964

Issued to:
Applicant:
Vatan Kablo
Velimese OSB Mahallesi 111.
Sokak No.:4/1 Ergene
59870 TEKIRDAG
Türkiye

Licensee:

Vatan Kablo Velimese OSB Mahallesi 111. Sokak No.:4/1 Ergene 59870 TEKIRDAG Türkiye

Product


: cables for fixed wiring

Trade name(s)

: VATAN

Type(s)/model(s)

: XVB



SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1600

SGS CEBEC hereby grants the right to use the CEBEC certification mark
The CEBEC certification mark may be applied to the product as specified in
this licence for the duration of the CEBEC certification agreement and under the
conditions of the CEBEC certification agreement.

This licence is issued on

11/12/2023

ir. C. Lana,

Certification Manager

© Only integral publication of this certificate, including the annex, is allowed This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee







This certificate is issued by the company under its General Conditions for Certification Services accessible at https://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : cables for fixed wiring

Trade name(s) : VATAN

Type(s)/Model(s) : XVB

description : cable with copper conductors, unarmoured, XLPE insulated

and PVC sheathed

rated voltage Uo/U : 0.6/1 kV

Fire propagation : min Cca-s3,d2,a3

TESTS

Test requirements

NBN HD 604:2016 + Corrigendum 2017-01 + AC 2018-08

Test results

The test results are laid down in test reports ref. 633006.01a and 633006.01b

Remarks

Covered number of conductors(round type) and cross sections

1-core: 16 mm² to 50 mm² 2-core: 1.5 mm² to 35 mm² 3-core: 1.5 mm² to 50 mm²

3+1-core: 25mm²+16mm², 35mm²+16mm², 50mm²+25mm²

4-core: 1.5 mm² to 50 mm² 5-core: 1.5 mm² to 25 mm²

ANNEX TO CEBEC LICENCE No. 22964 Page 2 of 3



Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi

Luigi Zanutto - 11/12/2023

Certification Manager

2023-12-1

ANNEX TO CEBEC LICENCE No. 22964 Page 3 of 3

SGS

FACTORY LOCATION(S)

Vatan Kablo Velimese OSB Mahallesi 111. Sokak No.:4/1 Ergene 59870 TEKIRDAG Türkiye